

East Lake Sammamish Trail Inglewood Hill Road Prarking Lot SSDP2017-00414 - Eastside Fire and Rescue

I. Fire Prevention Bureau Plan Review, dated March 30, 2017		
Item/Topic	Comment	King County Responses
1	Fire lanes shall be striped or signs installed at entrance and exit. Please submit fire lane plan to Eastside Fire & Rescue for review. If using signs please provide a sign detail of the "No Parking Fire Lane" for review.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.