

Web: <u>www.sammamish.us</u> www.mybuildingpermit.com

SMC 16.05.153

## **Electrical Permit Checklist**

This checklist is only required for specific types of electrical work. See Page 2 of the <u>Electrical Permit Application</u> for applicable scenarios.

## **Submittal Documents**

<u>Electrical Permit Application (completely filled out)</u>

□ For **residential roof-mounted solar panels**, use the <u>Electrical Permit Checklist for Residential Solar</u> <u>Photovoltaic Systems</u> instead of this checklist.

□ Electrical plans (not required for one and two-family dwellings). Show the following, as applicable. See Electrical Permit Application for information regarding when electrical plans are required.

□ **Floor plan** or site layout to show the area where the electrical work is to occur.

□ North arrow indicating the direction north.

 $\Box$  The **proposed use or occupancy** of the various portions of the building in which the electrical work is to occur.

 $\Box$  A complete **riser diagram**.

□ The calculated **load schedule and demand factor** selected for each branch circuit, feeder, sub-feeder, main feeder, service panel, and circuit schedules shall be shown.

□ Fault current calculations and the listed interrupting rating for each service and/or feeder.

 $\Box$  Legend or key to any symbols used.

Letters and numbers designating mains, feeders, branch circuits, and distribution panels. Wattage, number of sockets and types of **lighting fixtures**.

□ Wattage and purpose of **all other outlets**.

- □ **Voltage** at which any equipment will operate.
- □ Identification of size of wires, type of insulation, and all conduit sizes.

□ Lighting Budget Calculations (not required for one and two-family dwellings). Compliance forms and related information may be found at the Northwest Energy Efficiency Council (NEEC).

□ Any other information pertinent to the project, or as required by the plans examiner.

□ Engineer's stamp and signature on the electrical plans in the following cases:

- Educational facilities, hospitals and nursing homes.
- Services or feeders rated 1600 amperes or larger.
- Installations identified in the NEC that require engineering supervision.
- As required by the Building Official for installations which by their nature are complex, hazardous or pose unique design problems.

□ Owner/Renter/Lessee Affidavit to be provided when the property owner, renter or lessee chooses to purchase a permit to do an electrical installation on his/her own or qualified leased property under the conditions as described in RCW 19.28.261.